

OCEAN SYSTEMS LABORATORY, INC.

6194 Estate Frydenhoj

St. Thomas, St. Thomas, VI 00802-0000

Tel: (340) 714-1911 || Fax: (340) 777-2711

http://OceanSystemsLab.com || jean@oceansystemslab.com

MONTHLY COLIFORM ANALYSIS FORM / CHAIN OF CUSTODY

System Name: **Bouderant Technologies**

PWS ID: 0000000

Type ID:

Sample Loc: See Below For Location

Sampler: Delivered to Lab

Phone:

Route No:

Email:

Physical Location

St. Thomas

St. Thomas, St. Thomas, VI 00802-0000

Contact:

Phone: (787) 354-8348

Cell: Fax:

Email: alkinp0123@yahoo.com

Mailing Location

St. Thomas

St. Thomas, St. Thomas, VI 00802-0000

Manager:

Phone:

Cell: Fax:

Email:

Last Sample Date: 05/30/2018

Last Arsenic:

Last Disinfection By Product:

Last IOC:

Last Cyanide:

Last Lead/Copper:

Last VOC:

Last Nitrate:

Last Radiological:

Sample Number: 47299

Sample Type: Special

Sampler: Brown, Charles (Signature on File)

Volume: 100 (ml)

Date Taken: 05/30/2018 Time: 11:35

Chlorine: NT

Sample Location: Sample 3 After

Turbidity: 0.97

Received By: Thompson, Nikita (Signature on File)

Background: 5

Date Received: 05/30/2018 Time: 14:32

Total Coliform: A (A or P)

Temperature: 10 (° Centigrade) IPC: Yes

Fecal Coliform: (A or P; NA)

Analyst: Thompson, Nikita (Signature on File)

E. coli: (A or P)

Date Analyzed: 05/30/2018 Time: 16:55

pH:

Method: MF

TDS: (mg/L)

Retest Necessary: No (Yes / No)

Definitions: A: Absence; P: Present

IPC: In Process of Cooling (Samples arrived in cooler with ice or ice packs.)

MF: Membrane Filtration SM 20th Ed. 9222B, 9221E (fecal coliform), 9221 F (e.coli)

Colilert-18: SM 20th Ed. 9223

Maximum Contamination Limit: Turbidity - 1; Coliform - Negative; TDS - 500 mg/L; pH - 6.5 to 8.5

Comments / Notes: Computer Default: Fecal N/A